



## MEDIA INFORMATION / PUBLIC INFORMATION WORKSHEET

Please email to PIO Larry Gallegos at [lagallegos@bernco.gov](mailto:lagallegos@bernco.gov) (505) 228-6668

1. Date/Incident number	07/02/2017 2017-010
2. Incident Address	Reading Rd SE@Coso Ave SE
3. Area of County	South Valley
4. Mutual Aid request/given	None
5. Reported by:	Alarm Company
6. Fire Condition/Alarms (working fire, 2 <sup>nd</sup> alarm)	Initial call was for a heat detector activation. Upon arrival found commercial structure with a working fire
7. Size & Type of Structure/Incident (apt/residential home/ bldg)	Large 59000 square foot single story office/warehouse commercial structure
8. Number of Personnel Responded (Units and FFs)	Initial:12 Structure fire:23
9. Time Dispatched/1 <sup>st</sup> Unit Arrival time	08:33 Arrived 08:42 *9 minutes
10. Brief description of what 1 <sup>st</sup> unit on the scene saw.	Smoke showing from the south west corner
11. Total time to bring fire under control	15 minutes
12. Anyone inside at the time of the fire. If yes, how many	None
13. How was family alerted? (smoke detector, neighbors)	N/A
14. Injuries? If yes, include age, gender, transport info & injuries sustained.	none
15. Fire Origin? Was it contained to origin?	Utility room
16. Spread through %	< 5%
17. Smoke Damage (light or heavy smoke damage throughout)	Light smoke damage outside of room
18. Cause (determined/undetermined -->accident,natural,incendiary)	Items stored too close to the water heater burner area. Exterior heat shield for water heater was removed and not replaced.
19. Estimated Damages (structural, contents/vehicle)	\$2000
20. Assisting Agencies like Red Cross, # of displaced?	None
21. Contributing factors such as wind or location	Access was hindered by chained gates
22. Additional information (rescues, FF injuries and so on)	
23. On Scene POC	Battalion 8
24. Community Risk Reduction Message	Do not store items within three feet of water heater. Do not store items in a water heater closet in a commercial structure.
25. Additional Information	